


Rain Defence Louvres

B-7505 | Technical Datasheet






 www.c-sgroup.co.uk/19022

Rain Defence Louvres

B-7505 | Technical Datasheet

STANDARD DETAIL



 www.c-sgroup.co.uk/19022

All dimensions in millimeters unless otherwise stated. Do not scale from the drawing.


Rain Defence Louvres

B-7505 | Technical Datasheet

STANDARD DETAIL


With Insect Mesh or Bird Guard

INSECT MESH




Fiberglass Mesh
Black PVC coated
(1:2 @A4)
LV-1008
72% Free Area



BIRD / VERMIN GUARDS



Galvanized Welded
Mesh - (Standard)
(1:4 @A4)
LV-1408
85% Free Area



Flattened Aluminium
38-85AF - (Option)
(1:4 @A4)
LV-0158
73% Free Area




EXPLODED DETAIL

Bird Guard / Insect Mesh

Welded Aluminium frame to
secure the guard / mesh

Rivets fixing both guard / mesh
and frame to Louvre Frame

SECTION ON ELEVATION (1:8 @A4)



PLAN VIEW (1:8 @A4)


All dimensions in millimeters unless otherwise stated. Do not scale from the drawing.

Rain Defence Louvres


B-7505 | Technical Datasheet

STANDARD DETAIL

With Single Skin Blanking Panel



SECTION ON ELEVATION (1:8 @A4)



PLAN VIEW (1:8 @A4)

All dimensions in millimeters unless otherwise stated. Do not scale from the drawing.

Rain Defence Louvres

B-7505 | Technical Datasheet

STANDARD DETAIL


With Single Skin Blanking Panel

NOTE:


Insulation material options include:

- Non-combustible, A1 classified (to EN 13501-1) high strength stone wool core faced with open filament net
- Extruded polystyrene core

Panel thicknesses will vary, depending on the chosen core type and project's insulation requirements.



SECTION ON ELEVATION (1:8 @A4)







PLAN VIEW (1:8 @A4)

All dimensions in millimeters unless otherwise stated. Do not scale from the drawing.


Rain Defence Louvres

B-7505 | Technical Datasheet

APPENDIX A - FREE AREA



Free Area Between Blades



The percentage free area between the blades is calculated by taking the narrowest gap between the blades and dividing it by the blade pitch.

$$26.62/50.8 = 52.4\%$$

Free Area

Total free area is determined by multiplying the sum of the minimum distance between intermediate blades, top blade and head, and bottom blade and cill, by the minimum distance between jambs.

Percentage free area is calculated by dividing the total free area by the overall louvre size.

Example based on 2m x 2m louvre

- No. of blades - 38
- A - No. of unobstructed gaps between blades - 36
- B - Top gap - 12.23mm
- C - Blade gap - 26.62mm
- D - Bottom gap - 25.79
- E - Width between jambs - 1956mm

Total Free Area

$$((B + (C \times A) + D) \times E)$$

$$((0.01223 + (0.02662 \times 36) + 0.02579) \times 1.956) = 1.949\text{m}^2$$

Percentage Free Area

$$1.949/4 = 48.7\%$$

Approximate Free Area

Total Free Area

Opening at rear of louvre x percentage free area between blades

$$1.894 \times 1.956 \times 52.4\% = 1.941\text{m}^2$$

Percentage Free Area

$$1.941/4 = 48.5\%$$

All dimensions in millimeters unless otherwise stated. Do not scale from the drawing.